| Pile name | Volume (cu/yds) | Start date | PFRP date | End date | Hours monitoring | Hours Turning | Hours Building or Moving pile | Hours other (troubleshooting loggers) | Total human labor hours | Total Tractor hours | Person Labor hours/yd | Tractor Labor hours/yd | |
|--------------|--------------------|---------------|--------------|--------------|---------------------|------------------|-------------------------------------|---|-------------------------|---------------------------|-----------------------------|------------------------------|--|
| ASP1 | 66 | 5/1 | 5/20* | 6/17 | 0 | 0 | 8 | 1 | 8 | 8 | 0.12 | 0.12 | |
| TW1 | 80 | 5/15 | N/A | 6/17 | 1 | 2.5 | 8.5 | 1 | 12 | 11 | 0.15 | 0.14 | |
| ASP2 | 64 | 6/28 | 7/3 | 9/8 | 1.25 | 0 | 10.5 | 2 | 11.75 | 10.5 | 0.18 | 0.16 | |
| TW2 | 63 | 7/17 | N/A | 9/8 | 1.25 | 0.5 | 7 | 2 | 8.75 | 7.5 | 0.14 | 0.12 | |
| Notes: | | | | | | | | | | | | | |
| Neither TV | V pile met P | FRP temp | s- TW1 tem | nps dropped | d below 131F b | oetween turni | ngs; TW2 was o | only turned once | | | | | |
| ASP piles | have differe | nt PFRP : | standards, e | easier to me | eet because sh | orter window | of time and no | turning required. Also | seemed to sho | w higher cor | sistent temps | S. | |

Hours spent troubleshooting loggers was noted but not included in the final labor hours/pile equation, since that is assumed to not be a consistent factor in composting operations

In the case of TW2, the pile was only turned once