



## CLIENT INFORMATION

**Client:** Jonah Freeland  
**Requested On:** Apr 24, 2025  
**Phone:**  
**Email:** [freeland@humanimalbond.org](mailto:freeland@humanimalbond.org)

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:

[support@mytapscore.com](mailto:support@mytapscore.com)

Do not contact facility technicians directly.

## TESTING PERFORMED

**Testing Requested:** Advanced Home Water Test  
**Matrix:** Drinking Water  
**Testing / Report ID:** 8TQ62Z  
**Testing Facility:** Microbac Laboratories  
**Facility Location:** 428 Route 315 Hwy  
Pittston, Pennsylvania 18640

## SAMPLE INFORMATION

**Collection Date:** Jun 9, 2025  
**Collected By:** Jonah Freeland  
**Received Date:** Jun 11, 2025  
**Reported On:** Jun 18, 2025  
**Sample Location:** City Water Hydrant  
**Sample Address:** 217 Morgan Hill Road, Morgantown,  
WV 26508, United States

## TESTING NOTES FROM TAP SCORE

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact [support@mytapscore.com](mailto:support@mytapscore.com)

## SUMMARY ANALYSIS

| ANALYTE                    | UNIT   | RESULT | METHOD      | EPA REG |
|----------------------------|--------|--------|-------------|---------|
| pH                         | pH     | 7.71   | SM 4500-H+B | OK      |
| Total Dissolved Solids     | mg/L   | 146    | SM 2510 B   |         |
| Turbidity                  | NTU    | 0.75   | EPA 180.1   |         |
| Hardness (Ca,Mg)           | mg/L   | 73.9   |             |         |
| Hardness (Total)           | mg/L   | 76.3   |             |         |
| Grains per gallon          | Grains | 4.46   |             |         |
| Alkalinity (as CaCO3)      | mg/L   | 30     | SM 2320 B   |         |
| Langelier Saturation Index |        | -1     |             |         |
| Sodium Adsorption Ratio    |        | 0.35   |             |         |
| Total THMs                 | µg/L   | 65.57  |             |         |

## TEST RESULTS

| ANALYTE                   | UNIT | RESULT       | MDL   | RL  | METHOD    | EPA REG |
|---------------------------|------|--------------|-------|-----|-----------|---------|
| 1,1,1,2 Tetrachloroethane | µg/L | NOT DETECTED | 0.295 | 0.5 | EPA 524.2 |         |
| 1,1,1 Trichloroethane     | µg/L | NOT DETECTED | 0.395 | 0.5 | EPA 524.2 |         |
| 1,1,2,2 Tetrachloroethane | µg/L | NOT DETECTED | 0.31  | 0.5 | EPA 524.2 |         |
| 1,1,2 Trichloroethane     | µg/L | NOT DETECTED | 0.305 | 0.5 | EPA 524.2 |         |
| 1,1 Dichloroethane        | µg/L | NOT DETECTED | 0.355 | 0.5 | EPA 524.2 |         |

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

|                                |      |              |         |        |             |            |
|--------------------------------|------|--------------|---------|--------|-------------|------------|
| 1,1 Dichloroethylene           | µg/L | NOT DETECTED | 0.326   | 0.5    | EPA 524.2   |            |
| 1,1 Dichloropropene            | µg/L | NOT DETECTED | 0.323   | 0.5    | EPA 524.2   |            |
| 1,2,3 Trichlorobenzene         | µg/L | NOT DETECTED | 0.292   | 0.5    | EPA 524.2   |            |
| 1,2,3 Trichloropropane         | µg/L | NOT DETECTED | 0.315   | 0.5    | EPA 524.2   |            |
| 1,2,4 Trichlorobenzene         | µg/L | NOT DETECTED | 0.317   | 0.5    | EPA 524.2   |            |
| 1,2,4 Trimethylbenzene         | µg/L | NOT DETECTED | 0.314   | 0.5    | EPA 524.2   |            |
| 1,2 Dichlorobenzene            | µg/L | NOT DETECTED | 0.318   | 0.5    | EPA 524.2   |            |
| 1,2 Dichloroethane             | µg/L | NOT DETECTED | 0.365   | 0.5    | EPA 524.2   |            |
| 1,2 Dichloropropane            | µg/L | NOT DETECTED | 0.289   | 0.5    | EPA 524.2   |            |
| 1,3,5 Trimethylbenzene         | µg/L | NOT DETECTED | 0.326   | 0.5    | EPA 524.2   |            |
| 1,3 Dichlorobenzene            | µg/L | NOT DETECTED | 0.328   | 0.5    | EPA 524.2   |            |
| 1,3 Dichloropropane            | µg/L | NOT DETECTED | 0.268   | 0.5    | EPA 524.2   |            |
| 1,4 Dichlorobenzene            | µg/L | NOT DETECTED | 0.281   | 0.5    | EPA 524.2   |            |
| 2,2 Dichloropropane            | µg/L | NOT DETECTED | 0.255   | 0.5    | EPA 524.2   |            |
| Aluminum                       | mg/L | 0.614        | 0.0689  | 0.2    | EPA 200.7   |            |
| Antimony                       | mg/L | NOT DETECTED | 3.0E-5  | 0.0004 | EPA 200.8   |            |
| Arsenic                        | mg/L | NOT DETECTED | 0.00015 | 0.001  | EPA 200.8   |            |
| Barium                         | mg/L | 0.0338       | 4.0E-5  | 0.0004 | EPA 200.8   | < MCL (2)  |
| Benzene                        | µg/L | NOT DETECTED | 0.332   | 0.5    | EPA 524.2   |            |
| Beryllium                      | mg/L | NOT DETECTED | 4.0E-5  | 0.0004 | EPA 200.8   |            |
| Bicarbonate                    | mg/L | 36.37        |         |        | Bicarbonate |            |
| Boron                          | mg/L | NOT DETECTED | 0.0091  | 0.03   | EPA 200.7   |            |
| Bromobenzene                   | µg/L | NOT DETECTED | 0.302   | 0.5    | EPA 524.2   |            |
| Bromochloromethane             | µg/L | NOT DETECTED | 0.25    | 0.5    | EPA 524.2   |            |
| Bromodichloromethane           | µg/L | 6.46         | 0.295   | 0.5    | EPA 524.2   | < MCL (80) |
| Bromoform                      | µg/L | NOT DETECTED | 0.294   | 0.5    | EPA 524.2   |            |
| Bromomethane                   | µg/L | NOT DETECTED | 0.374   | 0.5    | EPA 524.2   |            |
| Cadmium                        | mg/L | NOT DETECTED | 3.0E-5  | 0.0004 | EPA 200.8   |            |
| Calcium                        | mg/L | 24.4         | 0.0446  | 0.2    | EPA 200.7   |            |
| Carbonate                      | mg/L | 0.086        |         |        | Carbonate   |            |
| Carbon Tetrachloride           | µg/L | NOT DETECTED | 0.306   | 0.5    | EPA 524.2   |            |
| Chloride                       | mg/L | 8.45         | 1.18    | 2.5    | EPA 300.0   |            |
| Chloride-to-Sulfate Mass Ratio |      | 0.22         |         |        | CSMR        |            |
| Chlorobenzene                  | µg/L | NOT DETECTED | 0.309   | 0.5    | EPA 524.2   |            |
| Chloroethane                   | µg/L | NOT DETECTED | 0.494   | 0.5    | EPA 524.2   |            |
| Chloroform                     | µg/L | 58.5         | 0.353   | 0.5    | EPA 524.2   | < MCL (80) |
| Chloromethane                  | µg/L | NOT DETECTED | 0.463   | 0.5    | EPA 524.2   |            |
| Chlorotoluene 2                | µg/L | NOT DETECTED | 0.407   | 0.5    | EPA 524.2   |            |
| Chlorotoluene 4                | µg/L | NOT DETECTED | 0.324   | 0.5    | EPA 524.2   |            |
| Chromium (Total)               | mg/L | NOT DETECTED | 0.00022 | 0.002  | EPA 200.8   |            |
| cis 1,2 Dichloroethylene       | µg/L | NOT DETECTED | 0.316   | 0.5    | EPA 524.2   |            |
| cis 1,3 Dichloropropene        | µg/L | NOT DETECTED | 0.264   | 0.5    | EPA 524.2   |            |
| Cobalt                         | mg/L | NOT DETECTED | 3.0E-5  | 0.0004 | EPA 200.8   |            |
| Copper                         | mg/L | NOT DETECTED | 0.00054 | 0.005  | EPA 200.8   |            |
| Dibromochloromethane           | µg/L | 0.61         | 0.216   | 0.5    | EPA 524.2   | < MCL (80) |

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

|                             |          |              |         |        |           |            |
|-----------------------------|----------|--------------|---------|--------|-----------|------------|
| Dibromochloropropane        | µg/L     | NOT DETECTED | 0.18    | 1      | EPA 524.2 |            |
| Dibromomethane              | µg/L     | NOT DETECTED | 0.231   | 0.5    | EPA 524.2 |            |
| Dichlorodifluoromethane     | µg/L     | NOT DETECTED | 0.325   | 0.5    | EPA 524.2 |            |
| Dichloromethane             | µg/L     | NOT DETECTED | 0.252   | 0.5    | EPA 524.2 |            |
| E. coli                     | P/A      | NOT DETECTED |         |        | SM 9223B  |            |
| Ethylbenzene                | µg/L     | NOT DETECTED | 0.313   | 0.5    | EPA 524.2 |            |
| Ethylene dibromide          | µg/L     | NOT DETECTED | 0.33    | 1      | EPA 524.2 |            |
| Fluoride                    | mg/L     | 0.69         | 0.04    | 0.5    | EPA 300.0 | < MCL (4)  |
| Hexachlorobutadiene         | µg/L     | NOT DETECTED | 0.221   | 0.5    | EPA 524.2 |            |
| Iron                        | mg/L     | NOT DETECTED | 0.0242  | 0.2    | EPA 200.7 |            |
| Isopropylbenzene            | µg/L     | NOT DETECTED | 0.463   | 0.5    | EPA 524.2 |            |
| Lead                        | mg/L     | NOT DETECTED | 5.0E-5  | 0.0004 | EPA 200.8 |            |
| Lithium                     | mg/L     | 0.00134      | 0.0001  | 0.001  | EPA 200.7 |            |
| Magnesium                   | mg/L     | 3.15         | 0.0123  | 0.2    | EPA 200.7 |            |
| Manganese                   | mg/L     | 0.000761     | 0.00017 | 0.0004 | EPA 200.8 |            |
| Mercury                     | mg/L     | NOT DETECTED | 5.0E-5  | 0.0008 | EPA 200.8 |            |
| Methyl Tertiary Butyl Ether | µg/L     | NOT DETECTED | 0.244   | 0.5    | EPA 524.2 |            |
| Molybdenum                  | mg/L     | NOT DETECTED | 4.0E-5  | 0.0004 | EPA 200.8 |            |
| m,p Xylene                  | µg/L     | NOT DETECTED | 0.673   | 1      | EPA 524.2 |            |
| Naphthalene                 | µg/L     | NOT DETECTED | 0.426   | 0.5    | EPA 524.2 |            |
| n Butylbenzene              | µg/L     | NOT DETECTED | 0.326   | 0.5    | EPA 524.2 |            |
| Nickel                      | mg/L     | NOT DETECTED | 0.00024 | 0.005  | EPA 200.8 |            |
| Nitrate (as N)              | mg/L     | 0.225        | 0.015   | 0.125  | EPA 300.0 | < MCL (10) |
| Nitrite (as N)              | mg/L     | NOT DETECTED | 0.05    | 0.125  | EPA 300.0 |            |
| n Propylbenzene             | µg/L     | NOT DETECTED | 0.357   | 0.5    | EPA 524.2 |            |
| o Xylene                    | µg/L     | NOT DETECTED | 0.345   | 0.5    | EPA 524.2 |            |
| Phosphorus                  | mg/L     | NOT DETECTED | 0.0294  | 0.2    | EPA 200.7 |            |
| p Isopropyltoluene          | µg/L     | NOT DETECTED | 0.267   | 0.5    | EPA 524.2 |            |
| Potassium                   | mg/L     | 1.16         | 0.0702  | 0.2    | EPA 200.7 |            |
| sec Butylbenzene            | µg/L     | NOT DETECTED | 0.303   | 0.5    | EPA 524.2 |            |
| Selenium                    | mg/L     | NOT DETECTED | 0.00021 | 0.001  | EPA 200.8 |            |
| Silica                      | mg/L     | 4.18         | 0.0667  | 0.214  | EPA 200.7 |            |
| Silver                      | mg/L     | NOT DETECTED | 0.0001  | 0.0004 | EPA 200.8 |            |
| Sodium                      | mg/L     | 6.94         | 0.134   | 0.2    | EPA 200.7 |            |
| Specific Conductivity       | umhos/cm | 249          | 1.77    | 2      | SM 2510 B |            |
| Strontium                   | mg/L     | 0.0837       | 0.00184 | 0.05   | EPA 200.7 |            |
| Styrene                     | µg/L     | NOT DETECTED | 0.291   | 0.5    | EPA 524.2 |            |
| Sulfate                     | mg/L     | 39.2         | 1.62    | 2.5    | EPA 300.0 |            |
| tert Butylbenzene           | µg/L     | NOT DETECTED | 0.326   | 0.5    | EPA 524.2 |            |
| Tetrachloroethylene         | µg/L     | NOT DETECTED | 0.313   | 0.5    | EPA 524.2 |            |
| Thallium                    | mg/L     | NOT DETECTED | 3.0E-5  | 0.0004 | EPA 200.8 |            |
| Tin                         | mg/L     | NOT DETECTED | 0.0002  | 0.0004 | EPA 200.8 |            |
| Titanium                    | mg/L     | 0.00317      | 0.00039 | 0.002  | EPA 200.7 |            |
| Toluene                     | µg/L     | NOT DETECTED | 0.321   | 0.5    | EPA 524.2 |            |
| Total Coliform              | P/A      | NOT DETECTED |         |        | SM 9223B  |            |

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

|                           |      |              |         |        |           |  |
|---------------------------|------|--------------|---------|--------|-----------|--|
| trans 1,3 Dichloropropene | µg/L | NOT DETECTED | 0.123   | 0.5    | EPA 524.2 |  |
| Trichloroethylene         | µg/L | NOT DETECTED | 0.311   | 0.5    | EPA 524.2 |  |
| Trichlorofluoromethane    | µg/L | NOT DETECTED | 0.34    | 0.5    | EPA 524.2 |  |
| Uranium                   | mg/L | NOT DETECTED | 5.0E-5  | 0.0004 | EPA 200.8 |  |
| Vanadium                  | mg/L | NOT DETECTED | 0.00036 | 0.002  | EPA 200.8 |  |
| Vinyl Chloride            | µg/L | NOT DETECTED | 0.485   | 0.5    | EPA 524.2 |  |
| Zinc                      | mg/L | NOT DETECTED | 0.00228 | 0.01   | EPA 200.7 |  |

#### How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).

This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

**How To Read Your SimpleLab PDF Report**

*Your results are being evaluated with the Health Guidance Level.*

*This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.*

*MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team are configured to measure.*



## Did you know?

This Tap Score report is easier to understand when viewed online.  
Access in-depth information about every detection, including health risks and treatment solutions.

[gosimplelab.com/signin](https://gosimplelab.com/signin)

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.



## CLIENT INFORMATION

**Client:** Jonah Freeland  
**Requested On:** Apr 24, 2025  
**Phone:**  
**Email:** [freeland@humanimalbond.org](mailto:freeland@humanimalbond.org)

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:  
[support@mytapscore.com](mailto:support@mytapscore.com)  
Do not contact facility technicians directly.

## TESTING PERFORMED

**Testing Requested:** Advanced Home Water Test  
**Matrix:** Drinking Water  
**Testing / Report ID:** STAKP8  
**Testing Facility:** Microbac Laboratories  
**Facility Location:** 428 Route 315 Hwy  
Pittston, Pennsylvania 18640

## SAMPLE INFORMATION

**Collection Date:** Jun 9, 2025  
**Collected By:** Jonah Freeland  
**Received Date:** Jun 11, 2025  
**Reported On:** Jun 18, 2025  
**Sample Location:** Well Pump  
**Sample Address:** 217 Morgan Hill Road, Morgantown,  
WV 26508, United States

## TESTING NOTES FROM TAP SCORE

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact [support@mytapscore.com](mailto:support@mytapscore.com)

## SUMMARY ANALYSIS

| ANALYTE                    | UNIT   | RESULT       | METHOD      | EPA REG |
|----------------------------|--------|--------------|-------------|---------|
| pH                         | pH     | 7.86         | SM 4500-H+B | OK      |
| Total Dissolved Solids     | mg/L   | 447          | SM 2510 B   |         |
| Turbidity                  | NTU    | 80           | EPA 180.1   |         |
| Hardness (Ca,Mg)           | mg/L   | 340          |             |         |
| Hardness (Total)           | mg/L   | 425.07       |             |         |
| Grains per gallon          | Grains | 24.83        |             |         |
| Alkalinity (as CaCO3)      | mg/L   | 299          | SM 2320 B   |         |
| Langelier Saturation Index |        | 0.63         |             |         |
| Sodium Adsorption Ratio    |        | 0.23         |             |         |
| Total THMs                 | µg/L   | NOT DETECTED |             |         |

## TEST RESULTS

| ANALYTE                   | UNIT | RESULT       | MDL   | RL  | METHOD    | EPA REG |
|---------------------------|------|--------------|-------|-----|-----------|---------|
| 1,1,1,2 Tetrachloroethane | µg/L | NOT DETECTED | 0.295 | 0.5 | EPA 524.2 |         |
| 1,1,1 Trichloroethane     | µg/L | NOT DETECTED | 0.395 | 0.5 | EPA 524.2 |         |
| 1,1,2,2 Tetrachloroethane | µg/L | NOT DETECTED | 0.31  | 0.5 | EPA 524.2 |         |
| 1,1,2 Trichloroethane     | µg/L | NOT DETECTED | 0.305 | 0.5 | EPA 524.2 |         |
| 1,1 Dichloroethane        | µg/L | NOT DETECTED | 0.355 | 0.5 | EPA 524.2 |         |

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

|                                |      |                |         |        |             |              |
|--------------------------------|------|----------------|---------|--------|-------------|--------------|
| 1,1 Dichloroethylene           | µg/L | NOT DETECTED   | 0.326   | 0.5    | EPA 524.2   |              |
| 1,1 Dichloropropene            | µg/L | NOT DETECTED   | 0.323   | 0.5    | EPA 524.2   |              |
| 1,2,3 Trichlorobenzene         | µg/L | NOT DETECTED   | 0.292   | 0.5    | EPA 524.2   |              |
| 1,2,3 Trichloropropane         | µg/L | NOT DETECTED   | 0.315   | 0.5    | EPA 524.2   |              |
| 1,2,4 Trichlorobenzene         | µg/L | NOT DETECTED   | 0.317   | 0.5    | EPA 524.2   |              |
| 1,2,4 Trimethylbenzene         | µg/L | NOT DETECTED   | 0.314   | 0.5    | EPA 524.2   |              |
| 1,2 Dichlorobenzene            | µg/L | NOT DETECTED   | 0.318   | 0.5    | EPA 524.2   |              |
| 1,2 Dichloroethane             | µg/L | NOT DETECTED   | 0.365   | 0.5    | EPA 524.2   |              |
| 1,2 Dichloropropane            | µg/L | NOT DETECTED   | 0.289   | 0.5    | EPA 524.2   |              |
| 1,3,5 Trimethylbenzene         | µg/L | NOT DETECTED   | 0.326   | 0.5    | EPA 524.2   |              |
| 1,3 Dichlorobenzene            | µg/L | NOT DETECTED   | 0.328   | 0.5    | EPA 524.2   |              |
| 1,3 Dichloropropane            | µg/L | NOT DETECTED   | 0.268   | 0.5    | EPA 524.2   |              |
| 1,4 Dichlorobenzene            | µg/L | NOT DETECTED   | 0.281   | 0.5    | EPA 524.2   |              |
| 2,2 Dichloropropane            | µg/L | NOT DETECTED   | 0.255   | 0.5    | EPA 524.2   |              |
| Aluminum                       | mg/L | <b>1.43</b>    | 0.0689  | 0.2    | EPA 200.7   |              |
| Antimony                       | mg/L | NOT DETECTED   | 6.0E-5  | 0.0008 | EPA 200.8   |              |
| Arsenic                        | mg/L | <b>0.00451</b> | 0.00029 | 0.002  | EPA 200.8   | < MCL (0.01) |
| Barium                         | mg/L | <b>0.311</b>   | 9.0E-5  | 0.0008 | EPA 200.8   | < MCL (2)    |
| Benzene                        | µg/L | NOT DETECTED   | 0.332   | 0.5    | EPA 524.2   |              |
| Beryllium                      | mg/L | NOT DETECTED   | 8.0E-5  | 0.0008 | EPA 200.8   |              |
| Bicarbonate                    | mg/L | <b>362.06</b>  |         |        | Bicarbonate |              |
| Boron                          | mg/L | <b>0.136</b>   | 0.0091  | 0.03   | EPA 200.7   |              |
| Bromobenzene                   | µg/L | NOT DETECTED   | 0.302   | 0.5    | EPA 524.2   |              |
| Bromochloromethane             | µg/L | NOT DETECTED   | 0.25    | 0.5    | EPA 524.2   |              |
| Bromodichloromethane           | µg/L | NOT DETECTED   | 0.295   | 0.5    | EPA 524.2   |              |
| Bromoform                      | µg/L | NOT DETECTED   | 0.294   | 0.5    | EPA 524.2   |              |
| Bromomethane                   | µg/L | NOT DETECTED   | 0.374   | 0.5    | EPA 524.2   |              |
| Cadmium                        | mg/L | NOT DETECTED   | 6.0E-5  | 0.0008 | EPA 200.8   |              |
| Calcium                        | mg/L | <b>89</b>      | 0.0446  | 0.2    | EPA 200.7   |              |
| Carbonate                      | mg/L | <b>1.21</b>    |         |        | Carbonate   |              |
| Carbon Tetrachloride           | µg/L | NOT DETECTED   | 0.306   | 0.5    | EPA 524.2   |              |
| Chloride                       | mg/L | <b>12.4</b>    | 1.18    | 2.5    | EPA 300.0   |              |
| Chloride-to-Sulfate Mass Ratio |      | <b>0.73</b>    |         |        | CSMR        |              |
| Chlorobenzene                  | µg/L | NOT DETECTED   | 0.309   | 0.5    | EPA 524.2   |              |
| Chloroethane                   | µg/L | NOT DETECTED   | 0.494   | 0.5    | EPA 524.2   |              |
| Chloroform                     | µg/L | NOT DETECTED   | 0.353   | 0.5    | EPA 524.2   |              |
| Chloromethane                  | µg/L | NOT DETECTED   | 0.463   | 0.5    | EPA 524.2   |              |
| Chlorotoluene 2                | µg/L | NOT DETECTED   | 0.407   | 0.5    | EPA 524.2   |              |
| Chlorotoluene 4                | µg/L | NOT DETECTED   | 0.324   | 0.5    | EPA 524.2   |              |
| Chromium (Total)               | mg/L | NOT DETECTED   | 0.00043 | 0.004  | EPA 200.8   |              |
| cis 1,2 Dichloroethylene       | µg/L | NOT DETECTED   | 0.316   | 0.5    | EPA 524.2   |              |
| cis 1,3 Dichloropropene        | µg/L | NOT DETECTED   | 0.264   | 0.5    | EPA 524.2   |              |
| Cobalt                         | mg/L | <b>0.00791</b> | 6.0E-5  | 0.0008 | EPA 200.8   |              |
| Copper                         | mg/L | <b>0.388</b>   | 0.00108 | 0.01   | EPA 200.8   | < MCL (1.3)  |
| Dibromochloromethane           | µg/L | NOT DETECTED   | 0.216   | 0.5    | EPA 524.2   |              |

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

|                             |          |              |         |        |           |               |
|-----------------------------|----------|--------------|---------|--------|-----------|---------------|
| Dibromochloropropane        | µg/L     | NOT DETECTED | 0.18    | 1      | EPA 524.2 |               |
| Dibromomethane              | µg/L     | NOT DETECTED | 0.231   | 0.5    | EPA 524.2 |               |
| Dichlorodifluoromethane     | µg/L     | NOT DETECTED | 0.325   | 0.5    | EPA 524.2 |               |
| Dichloromethane             | µg/L     | NOT DETECTED | 0.252   | 0.5    | EPA 524.2 |               |
| E. coli                     | P/A      | NOT DETECTED |         |        | SM 9223B  |               |
| Ethylbenzene                | µg/L     | NOT DETECTED | 0.313   | 0.5    | EPA 524.2 |               |
| Ethylene dibromide          | µg/L     | NOT DETECTED | 0.33    | 1      | EPA 524.2 |               |
| Fluoride                    | mg/L     | NOT DETECTED | 0.04    | 0.5    | EPA 300.0 |               |
| Hexachlorobutadiene         | µg/L     | NOT DETECTED | 0.221   | 0.5    | EPA 524.2 |               |
| Iron                        | mg/L     | 38.7         | 0.0242  | 0.2    | EPA 200.7 |               |
| Isopropylbenzene            | µg/L     | NOT DETECTED | 0.463   | 0.5    | EPA 524.2 |               |
| Lead                        | mg/L     | 0.0155       | 9.0E-5  | 0.0008 | EPA 200.8 | > MCL (0.015) |
| Lithium                     | mg/L     | 0.00686      | 0.0001  | 0.001  | EPA 200.7 |               |
| Magnesium                   | mg/L     | 28.7         | 0.0123  | 0.2    | EPA 200.7 |               |
| Manganese                   | mg/L     | 3.48         | 0.00033 | 0.0008 | EPA 200.8 |               |
| Mercury                     | mg/L     | NOT DETECTED | 5.0E-5  | 0.0008 | EPA 200.8 |               |
| Methyl Tertiary Butyl Ether | µg/L     | NOT DETECTED | 0.244   | 0.5    | EPA 524.2 |               |
| Molybdenum                  | mg/L     | NOT DETECTED | 9.0E-5  | 0.0008 | EPA 200.8 |               |
| m,p Xylene                  | µg/L     | NOT DETECTED | 0.673   | 1      | EPA 524.2 |               |
| Naphthalene                 | µg/L     | NOT DETECTED | 0.426   | 0.5    | EPA 524.2 |               |
| n Butylbenzene              | µg/L     | NOT DETECTED | 0.326   | 0.5    | EPA 524.2 |               |
| Nickel                      | mg/L     | 0.0103       | 0.00047 | 0.01   | EPA 200.8 |               |
| Nitrate (as N)              | mg/L     | NOT DETECTED | 0.015   | 0.125  | EPA 300.0 |               |
| Nitrite (as N)              | mg/L     | NOT DETECTED | 0.05    | 0.125  | EPA 300.0 |               |
| n Propylbenzene             | µg/L     | NOT DETECTED | 0.357   | 0.5    | EPA 524.2 |               |
| o Xylene                    | µg/L     | NOT DETECTED | 0.345   | 0.5    | EPA 524.2 |               |
| Phosphorus                  | mg/L     | NOT DETECTED | 0.0294  | 0.2    | EPA 200.7 |               |
| p Isopropyltoluene          | µg/L     | NOT DETECTED | 0.267   | 0.5    | EPA 524.2 |               |
| Potassium                   | mg/L     | 3.02         | 0.0702  | 0.2    | EPA 200.7 |               |
| sec Butylbenzene            | µg/L     | NOT DETECTED | 0.303   | 0.5    | EPA 524.2 |               |
| Selenium                    | mg/L     | NOT DETECTED | 0.00043 | 0.002  | EPA 200.8 |               |
| Silica                      | mg/L     | 16.4         | 0.0667  | 0.214  | EPA 200.7 |               |
| Silver                      | mg/L     | NOT DETECTED | 0.00021 | 0.0008 | EPA 200.8 |               |
| Sodium                      | mg/L     | 9.61         | 0.134   | 0.2    | EPA 200.7 |               |
| Specific Conductivity       | umhos/cm | 767          | 1.77    | 2      | SM 2510 B |               |
| Strontium                   | mg/L     | 2.21         | 0.00184 | 0.05   | EPA 200.7 |               |
| Styrene                     | µg/L     | NOT DETECTED | 0.291   | 0.5    | EPA 524.2 |               |
| Sulfate                     | mg/L     | 16.9         | 1.62    | 2.5    | EPA 300.0 |               |
| tert Butylbenzene           | µg/L     | NOT DETECTED | 0.326   | 0.5    | EPA 524.2 |               |
| Tetrachloroethylene         | µg/L     | NOT DETECTED | 0.313   | 0.5    | EPA 524.2 |               |
| Thallium                    | mg/L     | NOT DETECTED | 7.0E-5  | 0.0008 | EPA 200.8 |               |
| Tin                         | mg/L     | 0.001        | 0.0003  | 0.0008 | EPA 200.8 |               |
| Titanium                    | mg/L     | 0.0341       | 0.00039 | 0.002  | EPA 200.7 |               |
| Toluene                     | µg/L     | 0.62         | 0.321   | 0.5    | EPA 524.2 | < MCL (1000)  |
| Total Coliform              | P/A      | DETECTED     |         |        | SM 9223B  |               |

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

|                           |      |              |         |        |           |  |
|---------------------------|------|--------------|---------|--------|-----------|--|
| trans 1,3 Dichloropropene | µg/L | NOT DETECTED | 0.123   | 0.5    | EPA 524.2 |  |
| Trichloroethylene         | µg/L | NOT DETECTED | 0.311   | 0.5    | EPA 524.2 |  |
| Trichlorofluoromethane    | µg/L | NOT DETECTED | 0.34    | 0.5    | EPA 524.2 |  |
| Uranium                   | mg/L | NOT DETECTED | 0.0001  | 0.0008 | EPA 200.8 |  |
| Vanadium                  | mg/L | NOT DETECTED | 0.00072 | 0.004  | EPA 200.8 |  |
| Vinyl Chloride            | µg/L | NOT DETECTED | 0.485   | 0.5    | EPA 524.2 |  |
| Zinc                      | mg/L | <b>0.174</b> | 0.00228 | 0.01   | EPA 200.7 |  |

#### How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).

This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

**How To Read Your SimpleLab PDF Report**

*Your results are being evaluated with the Health Guidance Level.*

*This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.*

*MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team are configured to measure.*



## Did you know?

This Tap Score report is easier to understand when viewed online.  
Access in-depth information about every detection, including health risks and treatment solutions.

[gosimplelab.com/signin](https://gosimplelab.com/signin)



## CLIENT INFORMATION

**Client:** Jonah Freeland  
**Requested On:** Apr 24, 2025  
**Phone:**  
**Email:** [freeland@humanimalbond.org](mailto:freeland@humanimalbond.org)

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:  
[support@mytapscore.com](mailto:support@mytapscore.com)  
Do not contact facility technicians directly.

## TESTING PERFORMED

**Testing Requested:** Advanced Home Water Test  
**Matrix:** Drinking Water  
**Testing / Report ID:** 6LNCDQ  
**Testing Facility:** Microbac Laboratories  
**Facility Location:** 428 Route 315 Hwy  
Pittston, Pennsylvania 18640

## SAMPLE INFORMATION

**Collection Date:** Jun 9, 2025  
**Collected By:** Jonah Freeland  
**Received Date:** Jun 11, 2025  
**Reported On:** Jun 18, 2025  
**Sample Location:** Rainwater Container  
**Sample Address:** 217 Morgan Hill Road, Morgantown,  
WV 26508, United States

## TESTING NOTES FROM TAP SCORE

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact [support@mytapscore.com](mailto:support@mytapscore.com)

## SUMMARY ANALYSIS

| ANALYTE                | UNIT   | RESULT       | METHOD      | EPA REG          |
|------------------------|--------|--------------|-------------|------------------|
| pH                     | pH     | 5.97         | SM 4500-H+B | Out of EPA Range |
| Total Dissolved Solids | mg/L   | 4.18         | SM 2510 B   |                  |
| Turbidity              | NTU    | 2            | EPA 180.1   |                  |
| Hardness (Ca,Mg)       | mg/L   | NOT DETECTED |             |                  |
| Hardness (Total)       | mg/L   | 0.028        |             |                  |
| Grains per gallon      | Grains | 0.0016       |             |                  |
| Alkalinity (as CaCO3)  | mg/L   | NOT DETECTED | SM 2320 B   |                  |
| Total THMs             | µg/L   | NOT DETECTED |             |                  |

## TEST RESULTS

| ANALYTE                   | UNIT | RESULT       | MDL   | RL  | METHOD    | EPA REG |
|---------------------------|------|--------------|-------|-----|-----------|---------|
| 1,1,1,2 Tetrachloroethane | µg/L | NOT DETECTED | 0.295 | 0.5 | EPA 524.2 |         |
| 1,1,1 Trichloroethane     | µg/L | NOT DETECTED | 0.395 | 0.5 | EPA 524.2 |         |
| 1,1,2,2 Tetrachloroethane | µg/L | NOT DETECTED | 0.31  | 0.5 | EPA 524.2 |         |
| 1,1,2 Trichloroethane     | µg/L | NOT DETECTED | 0.305 | 0.5 | EPA 524.2 |         |
| 1,1 Dichloroethane        | µg/L | NOT DETECTED | 0.355 | 0.5 | EPA 524.2 |         |
| 1,1 Dichloroethylene      | µg/L | NOT DETECTED | 0.326 | 0.5 | EPA 524.2 |         |
| 1,1 Dichloropropene       | µg/L | NOT DETECTED | 0.323 | 0.5 | EPA 524.2 |         |

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

|                                |      |              |         |        |             |           |
|--------------------------------|------|--------------|---------|--------|-------------|-----------|
| 1,2,3 Trichlorobenzene         | µg/L | NOT DETECTED | 0.292   | 0.5    | EPA 524.2   |           |
| 1,2,3 Trichloropropane         | µg/L | NOT DETECTED | 0.315   | 0.5    | EPA 524.2   |           |
| 1,2,4 Trichlorobenzene         | µg/L | NOT DETECTED | 0.317   | 0.5    | EPA 524.2   |           |
| 1,2,4 Trimethylbenzene         | µg/L | 0.87         | 0.314   | 0.5    | EPA 524.2   |           |
| 1,2 Dichlorobenzene            | µg/L | NOT DETECTED | 0.318   | 0.5    | EPA 524.2   |           |
| 1,2 Dichloroethane             | µg/L | NOT DETECTED | 0.365   | 0.5    | EPA 524.2   |           |
| 1,2 Dichloropropane            | µg/L | NOT DETECTED | 0.289   | 0.5    | EPA 524.2   |           |
| 1,3,5 Trimethylbenzene         | µg/L | NOT DETECTED | 0.326   | 0.5    | EPA 524.2   |           |
| 1,3 Dichlorobenzene            | µg/L | NOT DETECTED | 0.328   | 0.5    | EPA 524.2   |           |
| 1,3 Dichloropropane            | µg/L | NOT DETECTED | 0.268   | 0.5    | EPA 524.2   |           |
| 1,4 Dichlorobenzene            | µg/L | NOT DETECTED | 0.281   | 0.5    | EPA 524.2   |           |
| 2,2 Dichloropropane            | µg/L | NOT DETECTED | 0.255   | 0.5    | EPA 524.2   |           |
| Aluminum                       | mg/L | NOT DETECTED | 0.0689  | 0.2    | EPA 200.7   |           |
| Antimony                       | mg/L | NOT DETECTED | 3.0E-5  | 0.0004 | EPA 200.8   |           |
| Arsenic                        | mg/L | NOT DETECTED | 0.00015 | 0.001  | EPA 200.8   |           |
| Barium                         | mg/L | 0.000972     | 4.0E-5  | 0.0004 | EPA 200.8   | < MCL (2) |
| Benzene                        | µg/L | NOT DETECTED | 0.332   | 0.5    | EPA 524.2   |           |
| Beryllium                      | mg/L | NOT DETECTED | 4.0E-5  | 0.0004 | EPA 200.8   |           |
| Bicarbonate                    | mg/L | 0            |         |        | Bicarbonate |           |
| Boron                          | mg/L | NOT DETECTED | 0.0091  | 0.03   | EPA 200.7   |           |
| Bromobenzene                   | µg/L | NOT DETECTED | 0.302   | 0.5    | EPA 524.2   |           |
| Bromochloromethane             | µg/L | NOT DETECTED | 0.25    | 0.5    | EPA 524.2   |           |
| Bromodichloromethane           | µg/L | NOT DETECTED | 0.295   | 0.5    | EPA 524.2   |           |
| Bromoform                      | µg/L | NOT DETECTED | 0.294   | 0.5    | EPA 524.2   |           |
| Bromomethane                   | µg/L | NOT DETECTED | 0.374   | 0.5    | EPA 524.2   |           |
| Cadmium                        | mg/L | NOT DETECTED | 3.0E-5  | 0.0004 | EPA 200.8   |           |
| Calcium                        | mg/L | NOT DETECTED | 0.0446  | 0.2    | EPA 200.7   |           |
| Carbonate                      | mg/L | 0            |         |        | Carbonate   |           |
| Carbon Tetrachloride           | µg/L | NOT DETECTED | 0.306   | 0.5    | EPA 524.2   |           |
| Chloride                       | mg/L | NOT DETECTED | 1.18    | 2.5    | EPA 300.0   |           |
| Chloride-to-Sulfate Mass Ratio |      | NOT DETECTED |         |        | CSMR        |           |
| Chlorobenzene                  | µg/L | NOT DETECTED | 0.309   | 0.5    | EPA 524.2   |           |
| Chloroethane                   | µg/L | NOT DETECTED | 0.494   | 0.5    | EPA 524.2   |           |
| Chloroform                     | µg/L | NOT DETECTED | 0.353   | 0.5    | EPA 524.2   |           |
| Chloromethane                  | µg/L | NOT DETECTED | 0.463   | 0.5    | EPA 524.2   |           |
| Chlorotoluene 2                | µg/L | NOT DETECTED | 0.407   | 0.5    | EPA 524.2   |           |
| Chlorotoluene 4                | µg/L | NOT DETECTED | 0.324   | 0.5    | EPA 524.2   |           |
| Chromium (Total)               | mg/L | NOT DETECTED | 0.00022 | 0.002  | EPA 200.8   |           |
| cis 1,2 Dichloroethylene       | µg/L | NOT DETECTED | 0.316   | 0.5    | EPA 524.2   |           |
| cis 1,3 Dichloropropene        | µg/L | NOT DETECTED | 0.264   | 0.5    | EPA 524.2   |           |
| Cobalt                         | mg/L | NOT DETECTED | 3.0E-5  | 0.0004 | EPA 200.8   |           |
| Copper                         | mg/L | NOT DETECTED | 0.00054 | 0.005  | EPA 200.8   |           |
| Dibromochloromethane           | µg/L | NOT DETECTED | 0.216   | 0.5    | EPA 524.2   |           |
| Dibromochloropropane           | µg/L | NOT DETECTED | 0.18    | 1      | EPA 524.2   |           |
| Dibromomethane                 | µg/L | NOT DETECTED | 0.231   | 0.5    | EPA 524.2   |           |

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

|                             |          |                 |         |        |           |               |
|-----------------------------|----------|-----------------|---------|--------|-----------|---------------|
| Dichlorodifluoromethane     | µg/L     | NOT DETECTED    | 0.325   | 0.5    | EPA 524.2 |               |
| Dichloromethane             | µg/L     | NOT DETECTED    | 0.252   | 0.5    | EPA 524.2 |               |
| E. coli                     | P/A      | NOT DETECTED    |         |        | SM 9223B  |               |
| Ethylbenzene                | µg/L     | <b>0.65</b>     | 0.313   | 0.5    | EPA 524.2 | < MCL (700)   |
| Ethylene dibromide          | µg/L     | NOT DETECTED    | 0.33    | 1      | EPA 524.2 |               |
| Fluoride                    | mg/L     | NOT DETECTED    | 0.04    | 0.5    | EPA 300.0 |               |
| Hexachlorobutadiene         | µg/L     | NOT DETECTED    | 0.221   | 0.5    | EPA 524.2 |               |
| Iron                        | mg/L     | NOT DETECTED    | 0.0242  | 0.2    | EPA 200.7 |               |
| Isopropylbenzene            | µg/L     | NOT DETECTED    | 0.463   | 0.5    | EPA 524.2 |               |
| Lead                        | mg/L     | <b>0.00117</b>  | 5.0E-5  | 0.0004 | EPA 200.8 | < MCL (0.015) |
| Lithium                     | mg/L     | NOT DETECTED    | 0.0001  | 0.001  | EPA 200.7 |               |
| Magnesium                   | mg/L     | NOT DETECTED    | 0.0123  | 0.2    | EPA 200.7 |               |
| Manganese                   | mg/L     | <b>0.00176</b>  | 0.00017 | 0.0004 | EPA 200.8 |               |
| Mercury                     | mg/L     | NOT DETECTED    | 5.0E-5  | 0.0008 | EPA 200.8 |               |
| Methyl Tertiary Butyl Ether | µg/L     | NOT DETECTED    | 0.244   | 0.5    | EPA 524.2 |               |
| Molybdenum                  | mg/L     | NOT DETECTED    | 4.0E-5  | 0.0004 | EPA 200.8 |               |
| m,p Xylene                  | µg/L     | <b>2.42</b>     | 0.673   | 1      | EPA 524.2 |               |
| Naphthalene                 | µg/L     | NOT DETECTED    | 0.426   | 0.5    | EPA 524.2 |               |
| n Butylbenzene              | µg/L     | NOT DETECTED    | 0.326   | 0.5    | EPA 524.2 |               |
| Nickel                      | mg/L     | NOT DETECTED    | 0.00024 | 0.005  | EPA 200.8 |               |
| Nitrate (as N)              | mg/L     | NOT DETECTED    | 0.015   | 0.125  | EPA 300.0 |               |
| Nitrite (as N)              | mg/L     | NOT DETECTED    | 0.05    | 0.125  | EPA 300.0 |               |
| n Propylbenzene             | µg/L     | NOT DETECTED    | 0.357   | 0.5    | EPA 524.2 |               |
| o Xylene                    | µg/L     | <b>1.49</b>     | 0.345   | 0.5    | EPA 524.2 |               |
| Phosphorus                  | mg/L     | NOT DETECTED    | 0.0294  | 0.2    | EPA 200.7 |               |
| p Isopropyltoluene          | µg/L     | NOT DETECTED    | 0.267   | 0.5    | EPA 524.2 |               |
| Potassium                   | mg/L     | NOT DETECTED    | 0.0702  | 0.2    | EPA 200.7 |               |
| sec Butylbenzene            | µg/L     | NOT DETECTED    | 0.303   | 0.5    | EPA 524.2 |               |
| Selenium                    | mg/L     | NOT DETECTED    | 0.00021 | 0.001  | EPA 200.8 |               |
| Silica                      | mg/L     | NOT DETECTED    | 0.0667  | 0.214  | EPA 200.7 |               |
| Silver                      | mg/L     | NOT DETECTED    | 0.0001  | 0.0004 | EPA 200.8 |               |
| Sodium                      | mg/L     | NOT DETECTED    | 0.134   | 0.2    | EPA 200.7 |               |
| Specific Conductivity       | umhos/cm | <b>4.65</b>     | 1.77    | 2      | SM 2510 B |               |
| Strontium                   | mg/L     | NOT DETECTED    | 0.00184 | 0.05   | EPA 200.7 |               |
| Styrene                     | µg/L     | NOT DETECTED    | 0.291   | 0.5    | EPA 524.2 |               |
| Sulfate                     | mg/L     | NOT DETECTED    | 1.62    | 2.5    | EPA 300.0 |               |
| tert Butylbenzene           | µg/L     | NOT DETECTED    | 0.326   | 0.5    | EPA 524.2 |               |
| Tetrachloroethylene         | µg/L     | NOT DETECTED    | 0.313   | 0.5    | EPA 524.2 |               |
| Thallium                    | mg/L     | NOT DETECTED    | 3.0E-5  | 0.0004 | EPA 200.8 |               |
| Tin                         | mg/L     | NOT DETECTED    | 0.0002  | 0.0004 | EPA 200.8 |               |
| Titanium                    | mg/L     | NOT DETECTED    | 0.00039 | 0.002  | EPA 200.7 |               |
| Toluene                     | µg/L     | <b>3.2</b>      | 0.321   | 0.5    | EPA 524.2 | < MCL (1000)  |
| Total Coliform              | P/A      | <b>DETECTED</b> |         |        | SM 9223B  |               |
| trans 1,3 Dichloropropene   | µg/L     | NOT DETECTED    | 0.123   | 0.5    | EPA 524.2 |               |
| Trichloroethylene           | µg/L     | NOT DETECTED    | 0.311   | 0.5    | EPA 524.2 |               |

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

|                        |      |               |         |        |           |  |
|------------------------|------|---------------|---------|--------|-----------|--|
| Trichlorofluoromethane | µg/L | NOT DETECTED  | 0.34    | 0.5    | EPA 524.2 |  |
| Uranium                | mg/L | NOT DETECTED  | 5.0E-5  | 0.0004 | EPA 200.8 |  |
| Vanadium               | mg/L | NOT DETECTED  | 0.00036 | 0.002  | EPA 200.8 |  |
| Vinyl Chloride         | µg/L | NOT DETECTED  | 0.485   | 0.5    | EPA 524.2 |  |
| Zinc                   | mg/L | <b>0.0155</b> | 0.00228 | 0.01   | EPA 200.7 |  |

#### How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).

This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

### **How To Read Your SimpleLab PDF Report**

*Your results are being evaluated with the Health Guidance Level.*

*This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.*

*MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team are configured to measure.*



## **Did you know?**

This Tap Score report is easier to understand when viewed online.  
Access in-depth information about every detection, including health risks and treatment solutions.

[gosimplelab.com/signin](https://gosimplelab.com/signin)

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.